

Evaluation of false alarm rates of a walkthrough detection portal designed for detecting triacetone triperoxide (TATP) vapour from field test results and receiver operating characteristic (ROC) curves

Takada Y, Nagano H, Kawaguchi Y, Suzuki Y, Nakajima E, Sugiyama M, Sugaya M, Hashimoto Y, Sakairi M.

International journal of safety and security engineering
2012; 2(3):256-264

ARTICLE IDENTIFIERS

DOI: 10.2495/SAFE-V2-N3-256-264

PMID: unavailable

PMCID: not available

JOURNAL IDENTIFIERS

LCCN: not available

pISSN: 2041-9031

eISSN: 2041-904X

OCLC ID: 751782434

CONS ID: not available

US National Library of Medicine ID: not available

This article was identified from a query of the SafetyLit database.